

Table of Contents

I.	Purpose.....	2.....
II.	Scope.....	2.....
III.	Definitions.....	2.....
IV.	Responsibilities.....	2.....
V.	Reporting Procedures for Indoor Air Quality Concerns.....	3....
VI.	Investigation Procedures.....	3.....
VII.	Recordkeeping.....	3.....
VIII.	Regulatory Authority and Related Information.....	3.....
IX.	Contact Information.....	4.....
	Appendix 1 Indoor Air Quality Standards and Guidelines.....	5....

I. Purpose

Northwestern

- iii. Ensure acceptable indoor air quality is maintained on all University-owned property.

V. Reporting Procedures for Indoor Air Quality Concerns

- A. Emergency
For any emergency AQ concerns that pose

IX. ContactInformation

For questions contact Environmental Health and Safety at ehs@northwestern.edu

Facilities Customer Service Monday Friday 7:00 am - 5:00 pm

Evanston (847) 491-5201

Chicago (312) 503-8000

facilities@northwestern.edu

Appendix 1 – Indoor Air Quality Standards & Guidelines

Parameter	IDPH ¹	ASHRAE ²	OSHA PEL ³	ACGIH TLV ⁴
Humidity	20-60%	<65%	N/A	N/A
Temperature	68-75° (winter) 73-79° (summer)	68-75° (winter) 73-79° (summer)	N/A	N/A
Carbon Dioxide	600-1,000 ppm (<800 ppm floor or building average)	<700 ppm more than outdoor concentrations	5,000 ppm	5,000 ppm
Carbon Monoxide	9 ppm	9 ppm (8-hour average) 35 ppm (1-hour average)	50 ppm	25 ppm
Hydrogen Sulfide	<0.01 ppm	N/A	20 ppm	1 ppm
Ozone	0.08 ppm 0.15 mg/tic0S Tm	N/A	0.1 ppm	0.05 ppm

Particulates